

Lubrication Instructions For Ball Bearing Motors

Lubrication

This motor is supplied with pre-lubrication ball bearings. No lubrication required before start up.

Relubrication Intervals

The following intervals are suggested as a guide:

SUGGESTED RELUBRICATION INTERVALS		
HOURS OF SERVICE PER YEAR	H.P. RANGE	RELUBE INTERVAL
5,000	Sub Fractional to 7 1/2 10 to 40 50-200	5 Years 3 Years 1 Year
Continuous Normal Applications	Sub Fractional to 7 1/2 10 to 40 50 to 200	2 Years 1 Year 9 Months
Season Service Motor Idle 6 Months or More	All	1 Year (Beginning of Season)
Continuous High Ambients Dirty or Moist Locations High Vibrations Where Shaft End is Hot (Pumps-Fans)	Sub Fractional to 40 50 to 200	6 Months 3 Months

Lubrication

Use high quality ball bearing lubricant. Use consistency of lubricant suitable for class of insulation stamped on nameplate as follows:

LUBRICATION CONSISTENCY				
INSULATION CLASS	CONSISTENCY	TYPE	TYPICAL LUBRICATION	FRAME TYPE
B & F F & H	Medium	Polyurea	Shell Dolium R and/or Chevron SR1 2	Sub Fractional to 447T All

Procedure

If motor is equipped with Alemite fitting, clean tip of fitting and apply grease gun. Use 1 to 2 full strokes on motors in NEMA 215T frame and smaller. Use 2 to 3 strokes on NEMA 254T thru NEMA 365 T frame. Use 3 to 4 strokes on NEMA 404T frames and larger. On motors having drain plugs, remove drain plug and operate motor for 20 minutes before replacing drain plug.

On motors equipped with slotted head grease screw, remove screw and apply grease tube to hole. Insert 2 to 3 inch length of grease string into each hole on motors in NEMA 215T frame and smaller. Insert 3 to 5 inch length on larger motors. For motors having drain plug and operate motor for 20 minutes before replacing drain plug.

CAUTION: Keep lubricant clean. Lubricate motors at standstill. remove and replace drain plugs at standstill. Do not mix petroleum lubricant and silicone lubricant in motor bearings.



ELECTRIC MOTORS, GEARMOTORS AND DRIVES

LEESON ELECTRIC

GRAFTON, WISCONSIN 53024-0241 U.S.A.
TEL (262)377-8810 FAX (262)377-9025 www.leeson.com

Motovario Limited - sales@motovario.co.uk
A Subsidiary of Regal-Beloit Corporation

Installation Maintenance Instructions AC Induction Motors

Installation

After unpacking, check for damage. Be sure that shaft rotates freely. Before making electrical power connections, check for proper grounding of motor and application. All electrical contacts and connections must be properly insulated and enclosed. Couplings, belts, chains or other mounted devices must be in proper alignment, balance and secure to insure safe motor operation.

Electrical Wiring

Prior to connecting to the power line, check nameplate for proper voltage and rotation connection. This motor should be installed in compliance with the National Electrical Code and any other applicable codes. Voltage at motor not to exceed + or -10% of nameplate. Authorized person should make all electrical connections.

Mounting

This motor should be securely mounted to the application. Sufficient ventilation area should be provided to insure proper operation.

RECOMMENDED COPPER WIRE & TRANSFORMER SIZE

SINGLE PHASE MOTORS - 230 VOLTS						
H.P.	TRANSFORMER KVA	DISTANCE - MOTOR TO TRANSF. IN FT.				
		100	150	200	300	500
1 1/2	3	10	8	8	6	4
2	3	10	8	8	6	4
3	5	8	8	6	4	2
5	7 1/2	6	4	4	2	0
7 1/2	10	6	4	3	1	0

THREE PHASE MOTORS - 230 & 460 VOLTS							
H.P.	VOLTS	TRANSFORMER KVA	DISTANCE - MOTOR TO TRANSF. IN FT.				
			100	150	200	300	500
1 1/2	230	3	12	12	12	12	10
1 1/2	460	3	12	12	12	12	12
2	230	3	12	12	12	10	8
2	460	3	12	12	12	12	12
3	230	5	12	10	10	8	6
3	460	5	12	12	12	12	10
5	230	7	10	8	8	6	4
5	460	7	12	12	12	10	8
7 1/2	230	7 1/2	8	6	6	4	2
7 1/2	460	10	12	12	12	10	8
10	230	10	6	4	4	4	1
10	460	15	12	12	12	10	8
15	230	15	4	4	4	2	0
15	460	20	12	10	10	8	6
20	230	20	4	2	2	1	000
20	460		10	8	8	6	4
25	230		2	2	2	0	000
25	460	Consult	8	8	6	6	4
30	230	Local	2	1	1	00	0000
30	460	Power	8	6	6	4	2
40	230	Company	1	0	00	0000	300
40	460		6	6	4	2	0
50	230		1	0	00	0000	300
50	460		4	4	2	2	0
60	230		1	00	000	250	500
60	460		4	2	2	0	00
75	230		0	000	0000	300	500
75	460		4	2	0	00	000

